



# Product Evaluation

DR862 | 0617

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** DR-862

**Effective Date:** June 1, 2017

**Re-evaluation Date:** August 2020

**Product Name:** Series SHD-8700 Vinyl Single Outswing Side Hinged Door, Impact Resistant

**Manufacturer:** Custom Window Systems, Inc.  
1900 SW 44<sup>th</sup> Ave.  
Ocala, FL 34474  
(352) 368-6922

## General Description:

System	Description	Label Rating	Design Pressure Rating
1	SHD-8700 Single Outswing Door	SHD-C90 38x97 Missile Level D	+90/-100 psf

## Product Dimensions:

System	Overall Size	Panel Size	Daylight Opening
1	38" x 97"	35-5/8" x 95-1/8"	24-5/8" x 84-1/8"

## Hardware and Components:

System	Component	Quantity	Attachment Method
1	Adjustable Hinges by Hoppe	4	Install hardware in accordance with Custom Window System drawing No. TDI-817 Sheets 1 through 6 of 6. Drawing titled "8700 PVC Swing Door Impact", dated November 13, 2015, signed & sealed by Lucas A. Turner P.E. on September 29, 2016.
	Multipoint Lock by Paddock	1	
	Flush Bolt by Paddock	2	
	Lock Strike Plates (Each Strike Location)	1 ea.	

**Product Identification (Certification Label on Door):**

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR 138-746 Air/Water/Structural, CAR 138-279 Impact
	Product Name	8700 PVC Impact Outswing Single Door
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05, ASTM E 1886-02/05, ASTM E-1996-02/05 Missile Level D

**Impact Resistance:**

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Acceptance of Smaller Assemblies:** Door assemblies with dimensions equal to or smaller than those specified are acceptable with the limitations specified in this report.

**Installation:**

System	Impact Resistant	Requirement
1	Type of Installation	Install and anchor door in accordance with Custom Window System drawing No. TDI-817 Sheets 1 through 6 of 6. Drawing titled "8700 PVC Swing Door Impact", dated November 13, 2015, signed & sealed by Lucas A. Turner P.E. on September 29, 2016.
	Wall Framing	
	Fasteners	
	Fastener Location and Spacing	
	Fastener Penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.